

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1514/NPPSDR/2023-24

Dated : 11-03-2024

It is certified that an inspection team headed by Vindhyachal, Executive Officer
 (Name of Officer with Designation) From Nagar Palika Parishad Siddharth Nagar
 (Name of Department/ Office) inspected the **Raghuvar Prasad Jaiswal Saraswati Shishu Mandir**
Inter College, Tetari Bazar, Siddharthnagar (Name & Address of the School) on
11-03-2024 (Date of Inspection) and on the basis of Water test Report (Attached)
 bearing No. **2483** dated 20.01.2024 of District Level Water Analysis Laboratory U.P. Jal Nigam
 (Rural). Siddharth Nagar (PHED Lab) certified that the **Raghuvar Prasad Jaiswal Saraswati**
Shishu Mandir Inter College, Tetari Bazar, Siddharthnagar (Name of the School) has safe
 drinking water facilities for the students and members of staff of the institution. School is also
 maintains the hygienic sanitation condition in the school building & the campus as per the norms
 prescribed by the Central/State/U.T Govt.


The above valid for a period of 1 Year.

Signature with Seal :

Name :

Designation :

Name & Address of the office / Department:


 अधिशासी अधिकारी
 नगर पालिका परिषद
 सिद्धार्थनगर

To,

Principal
Raghuvar Prasad Jaiswal Saraswati
Shishu Mandir Inter College
Tetari Bazar Siddharth Nagar
 (Name & Address of the Institution)



Analysis Report
District Level Water Analysis Laboratory
U.P Jal Nigam (Rural), SIDDHARTH NAGAR, Uttar Pradesh, India



TC NO. 12336

Rept No	2483	Date	20-01-2024	Page No.	1
---------	------	------	------------	----------	---

Customer/Firm Name R.P.J. SARSAWATI SISHU MANDIR INTER COLLAGE (TETARI BAZAR)

Basic details of sample

District	Siddharth Nagar	Block/Tahsil	Naugarh
Gram Panchayat		Village/Mohalla	Indra Nagar
Habitation	Indra Nagar	Location/Site Name	Pithani Khurd
Water Source	Bore Well	Sample No.	2483
Quantity of Sample	1.5 ltr	Date of Sample Collection	20-01-2024
Receiving Date	20-01-2024	Analysis Start Date	20-01-2024
Sample Depositer	SUNIL GUPTA	Analysis Completion Date	20-01-2024

Technical Data of Analysis

S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Ph*	-	7.85	6.5-8.5	6.5-8.5	IS 3025 (Part 11) :2022
2	Turbidity *	(NTU)	3.06	1	5	IS 3025 (Part 10) : 2023
3	TDS*	(mg/L)	199.8	500	2000	IS 3025 (Part 16) : 2023
4	Chloride*	(mg/L)	15.0	250	1000	IS 3025 (Part 32): 2019
5	Total Alkalinity *	(mg/L)	480	200	600	IS 3025 (Part 23) : 2023
6	Total Hardness*	(mg/L)	385	200	600	IS 3025 (Part 21) : 2019
7	Sulphate*	(mg/L)	9.740	200	400	APHA 24 Edition -4500 SO4 method (Turbidity method):2023
8	Nitrate*	(mg/L)	0.067	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method:2023)
9	Fluoride*	(mg/L)	0.025	1	1.5	APHA 2024 Edition -4500-F Method C (Electrode Method) : 2023
10	Iron	(mg/L)	0.403	1	1	APHA 24 Edition -3500-Fe Method B (Phenanthroline Method) : 2023
11	E.coli	-	0.0	Shall Not Be Detected in 100 ml sample		APHA 23rd Edition -9211B
12	T.coli	-	0.0	Shall Not Be Detected in 100 ml sample		APHA 23rd Edition -9211B
13	Arsenic	(mg/L)	0.0	0.01	0.1	IS 3025 (Part 37) : 2022

- Note**
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.
 5. Star Indicate parameters are under NABL accreditation

Prepared By

Chemist

Authorized Signatory
Lab Incharge

End of the report

